D.C.RAVI. B.E.(Civil)
VIJAYANAGAR ENGINEERS,
CIVIL ENGINEERING CONSULTANTS,
NEAR GANESH GODOWN, T.B.DAM ROAD,
HOSPET. CELL NO: 94481 24860.
E-MAIL : dcrhpt1@gmail.com

Registration No.
CAT-1/VOI,/446/2000-2001.
F.NO.CC/ITO(Tech)/34AB/860/
CIT-HBL/2000-01.DATED:16 -10-2000.
APPROVED BANK PANEL ENGINEER OF SBI. & BOI
I.T. APPROVED VALUER.

STABILITY CERTIFICATE

1	Name of the Property ownar		**NARBADA DEVI MEMORIAL SCHOOL**	
2	Name of the Lease Holder		**Not Applicable**	
3	Location of Residential District/Sub District		**ISR Road, Chittawadagi, Hospet (Tq), Vijayanagar (Dist).**	
4	Built up area & Floor height			
	Builtup Area floor wise	Ground Floor (including Corridor)	502.88	Sq.mt.
		First Floor (Including Corridor)	502.88	Sq.mt.
		Second Floor (Including Corridor)	502.88	Sq.mt.
	Each Floor Height		12 Feet	
5	**GPS Co-ordinate**		**Latitude : 15°16'41.63"N** **Longitute : 76°22'50.62"E**	
6	a) Foundation		Load bearing spread foot foundation using size stone on CC Bed Concrete over good gravel strata in good condition.	
	b) Superstructure		*Size Stone of 18" Wall with RCC Lintel and RCC Beams* and RCC Slab work with Sufficient strength and in good Condition.	
	c) Doors and windows		Good	
	d) Wood work wrought and put up		- -	
	e) Roof		RCC Roof Slab with Weather Proof Course	
	f) Flooring		Cement Flooring in Each Floor	
	g) Misllaneous (Cracks, etc.)		Minor cracks in Corridor slab are Repaired and Seepage Problem also Repaired and Maintaining Well	
7	Any major defects noticed which will render the Building unsafe in any manner.		Nill	
8	Whether maintenance works have been done properly		Yes	
9	Whether the structure is sound and the future life of building		**The structure is structurally Sound and the expected future life is not less than 15-20 Years.**	

CERTIFICATE

This is to Certify that the Existing building belonging to

NARBADA DEVI MEMORIAL SCHOOL, HOSPET TQ, VIJAYANAGARA DIST. KARNATAKA

ISR road, Chittawadagi, Hospet Tq. Vijayanagara Dist. Has been inspected by me on this day 03.04.2024 and conducted the Non-destructive test for concrete structure and Safe Bearing Capacity for Soil on adjucent side of the building for confirmation of strata with strength and the reports are enclosed by verifying the structural documents with reference from structural engineer. The results are found to be satisfactory, hence the Building is fit for the purpose of built in good condition and the future expected life considering, utility and style is not less 15-20 Years

Place: Hosapete
Date : 04.04.2024

D.C. Ravi, B.E. (Civil)
Chartered Engineer
Reg. No. M-198667 7 Dt: 31-12-08
Beside Govt. Primary School,
T.B. Dam Road, Amaravathi,
HOSAPETE-583 201.
Ph: 08394-224860, Mob: 9448124860